



122 MADISON
SAN ANTONIO, TX 78204

PHONE: (210) 227-8786
FAX: (210) 227-8030

INFO@OURKWA.ORG
WWW.OURKWA.ORG

September 6, 2016

Historic and Design Review Commission
1901 S Alamo St
San Antonio, Texas 78204

Re: Case #2016-4767: 536 Adams St. – *King William District*
Certificate of Appropriateness – New Standing Seam Metal Roof

Dear HDRC Commissioners,

The King William Association Architectural Advisory Committee met to review the project and concurs with the OHP recommendation for approval provided that an example of a low profile galvalume roof ridge be submitted and approved. A 5"x5" ridge cap proposed on the small gambrel roof sections on the house will be over scaled and out of proportion with the smaller roof areas. Historically, roofs were galvanized with crimped seams and ridges that produced the low-profile look.

Best Regards,

Mickey Conrad
Chair, Architectural Advisory Committee

Harry Shafer
President, KWA Board of Directors